ZERTIFIKAT ◆ CERTIFICATE ◆ 認証証書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

CERTIFICATE

No. Z1A 11 12 12906 216

Holder of Certificate: **DÜPERTHAL SICHERHEITSTECHNIK GMBH & Co. KG**

Frankenstraße 3
63791 Karlstein
GERMANY

DÜPERTHAL®

Factory(ies): 62099

Certification Mark:

Product: **Safety cabinets**

Model(s): **UTS BASIC, 23-HHBBTu-xyz(ss)**

Parameters:

Key code Art.-No.

HH	height, stands for number 06
BB	width, stands for number 06, 11
T	depth, stands for number 5, 6
u	door technique, Stands for number 0, 3, 4, 5
x	colour, stands for number 4
yz	interior fitting, stands for number 00-99
ss	special sign, stands for L, R

Fire resistance FWF 30

Fire resistance: FWF 30
The material number defined exact material and size of the single products. A full description of the specifications is provided in the test report.

Tested according to:

DIN EN 14470-1:2004
DIN EN 14727:2006
EK5/AK4 09-10:2009

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

Test report no.: 71398430

Valid until: 2016-12-20

Date, 2011-12-21

(Edgar Harnisch)

509899

Page 1 of 1

TÜV SÜD Product Service GmbH · Zertifizierstelle · Ridlerstraße 65 · 80339 München · Germany

TÜV®