



Product Service

CERTIFICATE

No. Z1A 12 04 12906 224

Holder of Certificate: DÜPERTHAL SICHERHEITSTECHNIK
GMBH & Co. KG**DÜPERTHAL****Factory(ies):**Frankenstraße 3
63791 Karlstein
GERMANY

62099

Certification Mark:**Product:**

Safety cabinets

Model(s):

SUPPLY line, 49-20BBTu-xyz(ss)

Parameters:

Key code Art.-No.

BB width, stands for number 09, 17
 T depth, stands for number 7
 u door technique, stands for number 0, 1, 3
 x colour, stands for number 0, 4, 5, 6, 7
 yz interior fitting, stands for number 00
 ss special sign, stands for L, R, B

Fire resistance: FWF 90

The article number defines exactly material and size
 of the product. A detailed description of the parameters
 can be found in the test report.

Tested according to:

DIN EN 14470-1:2004
 DIN EN 14727:2006
 DIN EN 60079-10-1:2009
 PPP 52125A:2011
 TRbF 20:2002
 TRbF 30:2002
 EK5/AK4 09-10:2006

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

Test report no.: 713000440**Valid until:** 2017-04-30**Date,** 2012-05-02

(Edgar Harnisch)



Page 1 of 1